

MAGNATRON INTERNATIONAL
 5/C, Mitra Ghosh Street, Calcutta-700016
 PH: 91-33-2229 2767 MO: 9148727964 / 9331827964
 Email: info@magntro.com

MAS ENERGY SAVER

Date: 22/9/16

DEMO SHEET

I

COMPANY NAME Tata Power - DDI (Delhi Distribution Limited)
 SITE LOCATION C2, Lawrence Road, Kharabpuram, NDPL, New Delhi
 TYPE OF WORK AT LOCATION Office Room

II

AC SPEC.				
S.NO.	BRAND NAME	YEAR	MODEL	CAPACITY
1	<u>Volvo</u>			<u>1.5T₂</u>
2				
3				
4				

III

CLIMATIC CONDITION (FROM MET DEPT. REPORTS)		
DATE	OUTSIDE TEMPERATURE	CLOUDY/RAIN (Y/N)
<u>22/9/16</u>		<u>N</u>

IV

BYPASS MODE (WITHOUT MAS-ENERGY)

START				END				TOTAL UNITS CONSUMED (DIFF. OF A & B)
DATE	START TIME	A. METER READING (KWH)	ROOM TEMPERATURE	DATE	END TIME	B. METER READING (KWH)	ROOM TEMPERATURE	
<u>22/9/16</u>	<u>1:25</u>	<u>430.1</u>	<u>25°C</u>	<u>22/9/16</u>	<u>2:25</u>	<u>430.9</u>	<u>23°C</u>	<u>.8</u>

V

POWER SAVER MODE (WITH MAS-ENERGY)

START				END				TOTAL UNITS CONSUMED (DIFF. OF A & B)
DATE	START TIME	A. METER READING (KWH)	ROOM TEMPERATURE	DATE	END TIME	B. METER READING (KWH)	ROOM TEMPERATURE	
<u>22/9/16</u>	<u>2:30</u>	<u>431.0</u>	<u>25°C</u>	<u>22/9/16</u>	<u>3:30</u>	<u>431.5</u>	<u>23°C</u>	<u>.5</u>

VI

SAVINGS: (DIFF. IN TOTAL UNITS CONSUMED IN POWER SAVER MODE AND IN BYPASS MODE) 37.5%

VII

COMMENTS/OBSERVATIONS: Temperature is maintained with & without Energy Saver. * The above measurement taken through 1-0 class energy meter (Serial No. 08234, owned by M. Saptak Basak).

CUSTOMER'S SIGNATURE W. S. S. 08234, owned by M. Saptak Basak.
 STAMP
 CUSTOMER NAME Sandeep Sharma
 DESIGNATION Manager (E.N. 91619)
 CONTACT NO. 9810215951
 DATE 22/09/2016

TECH. REP. FOR MAGNATRON INTERNATIONAL
 SIGNATURE Basak
 NAME Saptak Basak
 DATE 22/09/2016

THE CUSTOMER HAS RECEIVED THE METER, METER READING AND OTHER RELEVANT RECORDS MENTIONED FOR PROPER VALIDATIONS